



MISSISSIPPI STATE DEPARTMENT OF HEALTH

RECEIVED - WATER SUPPLY

2021 JUN 21 AM 7:56

**2020 CERTIFICATION****Consumer Confidence Report (CCR)****Porterville Water Association & Porterville Water Association-Kemper Springs***Public Water System Name*

0350006 &amp; 0350024

*List PWS ID #s for all Community Water Systems included in this CCR*

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR.

**CCR DISTRIBUTION (Check all boxes that apply.)**

INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)	
<input checked="" type="checkbox"/> On water bills (Attach copy of bill)	5/27/21
<input type="checkbox"/> Email message (Email the message to the address below)	
<input type="checkbox"/> Other _____	
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Distributed via U. S. Postal Mail	
<input type="checkbox"/> Distributed via E-Mail as a URL (Provide Direct URL): _____	
<input type="checkbox"/> Distributed via E-Mail as an attachment	
<input type="checkbox"/> Distributed via E-Mail as text within the body of email message	
<input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	
<input checked="" type="checkbox"/> Posted in public places (attach list of locations)	5/27/21
<input type="checkbox"/> Posted online at the following address (Provide Direct URL): _____	

**CERTIFICATION**

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the MSDH, Bureau of Public Water Supply.

Name

Title

Date

**SUBMISSION OPTIONS (Select one method ONLY)****You must email, fax (not preferred), or mail a copy of the CCR and Certification to the MSDH.****Mail:** (U.S. Postal Service)**Email:** [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

MSDH, Bureau of Public Water Supply

**Fax:** (601) 576-7800(NOT PREFERRED)

P.O. Box 1700

Jackson, MS 39215

**CCR DEADLINE TO MSDH & CUSTOMERS: BY JULY 1, 2021**

*Annual Drinking Water Quality Report*  
*Porterville Water Association & Porterville Water Association - Kemper Springs*  
*PWS ID # 0350006 & 0350024*  
*May 2021*

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of 4 wells that draw from the Lower Wilcox, Coker Formation and Mass Sand Aquifers.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for Porterville Water Association and Porterville Water Association-Kemper Springs received one moderate and two higher susceptibility rankings to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Sue Stuart at 601-476-9614. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 4<sup>th</sup> Monday of each month at the Porterville Water Association office at 6:30 pm.

Porterville Water Association and Porterville Water Association-Kemper Springs routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2020. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Porterville Water Association - PWS ID # 0350006**
**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
8. Arsenic	N	2019*	4.3	No Range	Ppb	n/a	50	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2019*	0.1325	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2019*	0.6	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	1/1/18 to 12/31/20	0.1	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2019*	1.12	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	1/1/18 to 12/31/20	1.0	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2019*	3.4	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
<b>Disinfectants &amp; Disinfectant By-Products</b>								
Chlorine (as Cl <sub>2</sub> )	N	2020	1.40	0.0 to 2.30	ppm	4	4	Water additive used to control microbes
73. TTHM [Total trihalomethanes]	N	2020	1.47	No Range	ppb	0	80	By-product of drinking water chlorination
HAA5	N	2020	60	No Range	ppb	0	60	By-product of drinking water chlorination

\* Most recent sample results available

**Porterville Water Association-Kemper Springs - PWS ID # 0350024****TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Radioactive Contaminants</b>								
5. Alpha emitters	N	2019*	2.3	No Range	Pci/l	0	15	Erosion of natural deposits
6. Combined radium	N	2019*	2.1	No Range	Pci/l	0	5	Erosion of natural deposits
<b>Inorganic Contaminants</b>								
10. Barium	N	2019*	0.0173	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2020	0.5	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
19. Nitrate (as Nitrogen)	N	2020	0.26	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>Disinfectants &amp; Disinfectant By-Products</b>								
Chlorine (as Cl <sub>2</sub> )	N	2020	1.40	1.20 to 1.80	ppm	4	4	Water additive used to control microbes
HAA5	N	2018*	1.0	No Range	ppb	0	60	By-product of drinking water chlorination

\* Most recent sample results available

**Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have any questions.

PROOF OF PUBLICATION  
THE STATE OF MISSISSIPPI  
KEMPER COUNTY

PERSONALLY appeared before me, the undersigned notary public in and for Kemper County, Mississippi, for the KEMPER COUNTY MESSENGER, a weekly newspaper of general circulation in Kemper County, Mississippi as defined and prescribed in Section 13-3-31, of the Mississippi Code of 1972, as amended, who, being duly sworn, states that the notice, a true copy of which is attached hereto was published in the issues of said newspaper as follows:

Date 05/27, 2021

Vol. 87, No. 21

Date \_\_\_\_\_, 2021

Vol. \_\_\_\_\_, No. \_\_\_\_

Date \_\_\_\_\_, 2021

Vol. \_\_\_\_\_, No. \_\_\_\_

Date \_\_\_\_\_, 2021

Vol. \_\_\_\_\_, No. \_\_\_\_

Signed:

Morgan Sorrell  
For the  
KEMPER COUNTY MESSENGER

SWORN TO AND SUBSCRIBED before me the

1 day of June, 2021

Allie Hall  
Notary Public



*Annual Drinking Water Quality Report*  
**Porterville Water Association & Porterville Water Association - Kemper Springs**  
**PWS ID # 0350006 & 0350024**  
**May 2021**

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of 4 wells that draw from the Lower Wilcox, Coker Formation and Mass Sand Aquifers.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for Porterville Water Association and Porterville Water Association-Kemper Springs received one moderate and two higher susceptibility rankings to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Sue Stuart at 601-476-9614. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 4<sup>th</sup> Monday of each month at the Porterville Water Association office at 6:30 pm.

Porterville Water Association and Porterville Water Association-Kemper Springs routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2020. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Porterville Water Association - PWS ID # 0350006**

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
8. Arsenic	N	2019*	4.3	No Range	Ppb	n/a	50	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2019*	0.1325	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2019*	0.6	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	1/1/18 to 12/31/20	0.1	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2019*	1.12	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
				No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
<b>Disinfectants &amp; Disinfectant By-Products</b>								
Chlorine (as Cl <sub>2</sub> )	N	2020	1.40	0.0 to 2.30	ppm	4	4	Water additive used to control microbes
73. TTHM [Total trihalomethanes]	N	2020	1.47	No Range	ppb	0	80	By-product of drinking water chlorination
HAA5	N	2020	60	No Range	ppb	0	60	By-product of drinking water chlorination

\* Most recent sample results available

**Porterville Water Association-Kemper Springs - PWS ID # 0350024**

TEST RESULTS								
Contaminant	Violation	Date	Level	Range of Detects	Unit Measurement	MCLG	MCL	Likely Source of Contamination

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010104000	04/15	05/15
SERVICE ADDRESS		
959 DALE RD SCOOBA		
CURRENT	METER READINGS PREVIOUS	USED
541960	537220	4740
CHARGE FOR SERVICES		

RETURN THIS STUB WITH PAYMENT TO  
**PORTERVILLE WATER ASSOC.**  
 P.O. BOX 8  
 PORTERVILLE, MS 39352

PRESORTED  
 FIRST-CLASS MAIL  
 U.S. POSTAGE  
 PAID  
 PERMIT NO. 7  
 PORTERVILLE, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/10/2021	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
44.44	4.44	48.88

Consumer Confidence Report  
 Available in Office

WTR 44.44  
 NET DUE >>> 44.44  
 SAVE THIS >> 4.44  
 GROSS DUE >> 48.88

**RETURN SERVICE REQUESTED**

010104000  
 BARBARA EPPS

PO BOX 342  
 SCOOBA MS 39358-0342

